



Befestigungsschrauben sind nicht im
Lieferumfang enthalten
mounting screws are not included in
delivery



Achtung: Bei Kippfenster Sicherheitschere einbauen!

Diese Montageanleitung wendet sich an ausgebildetes Fachpersonal, Grundlegende Arbeitsschritte werden nicht näher erläutert
Achtung: Alle Maße und Befestigungen sind gem. VOB am Bau zu prüfen und ggf. anzupassen !
Die Montage- und Betriebsanleitung ist Bestandteil dieser Einbauzeichnung und ist daher zu beachten

Attention: Insert security stay with tilt window!

This assembly instructions apply to trained personnel, basic working steps are not explained
Attention: All dimensions and mountings are to be checked at the building and if necessary adapted!
The assembly and operating instruction are a component of this installation drawing and are from there to be considered

Bezeichnung / description	Artikel-Nr. / material number	Hub / stroke (mm)	Montagemaß / mounting dim. L3 (mm)	Gesamtlänge / total length L (mm)	Flügelhöhe / sash height min. (mm)	max. Schub-/Zugkraft shear-/tractive force
Eltral K60, 24V	K-17648-25-0-00	250	443	461	250	600N / 600N
Eltral K60, 24V, Synchro	K-17583-25-0-00		443	461		
Eltral K60, 230V	K-17649-25-0-00		519	537		
Eltral K60, 24V	K-17648-40-0-00	400	519	537	400	600N / 600N
Eltral K60, 24V, Synchro	K-17583-40-0-00		519	537		
Eltral K60, 230V	K-17649-40-0-00		595	613		
Eltral K60, 24V	K-17648-50-0-00	500	621	639	550	400N / 600N
Eltral K60, 24V	K-17648-60-0-00	600	621	639	700	300N / 600N
Eltral K60, 24V, Synchro	K-17583-60-0-00		621	639		
Eltral K60, 24V	K-17648-80-0-00	800	722	740	900	200N / 600N
Eltral K60, 24V	K-17648-01-0-00	1000	824	842	1200	100N / 600N

Description Montageanleitung ELTRAL K60, Kippfenster, Flügelmontage, Holzfenster, lange Konsole mounting instruction ELTRAL K60, tilt window, sash mounting, wood window, long console Bef.-Garn. / mounting set K-17640-00-0-0							
 	Release No. 7640	Level	release		Scale 1:2	Modification neu erstellt	Size 3
	Mod. No. G21703	Ver.	--	--			
		Draft	30.09.2008	FI		Drawing No. 0-44943-IE	Sheet 1/1
	Replacement for --						